



CERTIFICATE OF ANALYSIS
04/06/2007
GEORGE WEYMOUTH
6 AGAWAM CIR
BILLERICA, MA 01821
CONTACT: GEORGE WEYMOUTH

CUSTOMER ID: PS 160 CAULK **NEA ID:** AK02154 **NEA LRF:** 07030107-01
MATRIX: SOLID **DATE SAMPLED:** 02/11/2007 **TIME:** 13:05
DATE RECEIVED: 03/23/2007 **TIME:** 14:00 **PROJECT:** PS 160 EXTERIOR DOOR
SAMPLED BY: G. WEYMOUTH **LOCATION:** BRONX, NY
CUSTOMER PO: N/A **LAB ELAP#:** 11078

PARAMETER PERFORMED	RESULTS	PQL	UNITS	DATE ANALYZED	FLAGS
SW-846 8082 (PCB)					
Aroclor 1016	ND	7.20	ug/g	04/04/2007	U
Aroclor 1221	ND	7.20	ug/g	04/04/2007	U
Aroclor 1232	ND	7.20	ug/g	04/04/2007	U
Aroclor 1242	ND	7.20	ug/g	04/04/2007	U
Aroclor 1248	ND	7.20	ug/g	04/04/2007	U
Aroclor 1254	102	7.20	ug/g	04/04/2007	AF
Aroclor 1260	86.8	7.20	ug/g	04/04/2007	AG
Total PCB Amount > Reporting Limit	188.8				

Notes: ND (Not Detected). Denotes analyte not detected at a concentration greater than the PQL.
PQL (Practical Quantitation Limit). Denotes lowest analyte concentration reportable for the sample.
AF-Aroclor 1254 is being reported as the best Aroclor match. The sample exhibits an altered PCB pattern.
AG-Aroclor 1260 is being reported as the best Aroclor match. The sample exhibits an altered PCB pattern.

AUTHORIZED SIGNATURE:

William A. Kotas
Quality Assurance Officer

Robert E. Wagner
Laboratory Director