



CERTIFICATE OF ANALYSIS
04/06/2007
GEORGE WEYMOUTH
6 AGAWAM CIR
BILLERICA, MA 01821
CONTACT: GEORGE WEYMOUTH

CUSTOMER ID: BUILDING 2 COLUMN LINE
MATRIX: SOLID
DATE RECEIVED: 03/23/2007 **TIME:** 14:00
SAMPLED BY: G. WEYMOUTH
CUSTOMER PO: N/A

NEA ID: AK02159 **NEA LRF:** 07030112-01
DATE SAMPLED: 02/11/2007 **TIME:** 11:30
PROJECT: BUILDING 2 COLUMN
LOCATION: BRONX, NY
LAB ELAP#: 11078

PARAMETER PERFORMED	RESULTS	PQL	UNITS	DATE ANALYZED	FLAGS
SW-846 8082 (PCB)					
Aroclor 1016	ND	4040	ug/g	04/05/2007	U
Aroclor 1221	ND	4040	ug/g	04/05/2007	U
Aroclor 1232	ND	4040	ug/g	04/05/2007	U
Aroclor 1242	ND	4040	ug/g	04/05/2007	U
Aroclor 1248	ND	4040	ug/g	04/05/2007	U
Aroclor 1254	97600	4040	ug/g	04/05/2007	
Aroclor 1260	ND	4040	ug/g	04/05/2007	U
Total PCB Amount > Reporting Limit	97600				

Notes: ND (Not Detected). Denotes analyte not detected at a concentration greater than the PQL.
PQL (Practical Quantitation Limit). Denotes lowest analyte concentration reportable for the sample.

AUTHORIZED SIGNATURE:

William A. Kotas
Quality Assurance Officer
Robert E. Wagner
Laboratory Director