



**CERTIFICATE OF ANALYSIS**  
**05/14/2007**  
**GEORGE WEYMOUTH**  
**6 AGAWAM CIR**  
**BILLERICA, MA 01821**  
**CONTACT: GEORGE WEYMOUTH**

**CUSTOMER ID:** PS 153 WINDOW CAULK  
**MATRIX:** SOLID  
**DATE RECEIVED:** 03/23/2007 **TIME:** 14:00  
**SAMPLED BY:** G. WEYMOUTH  
**CUSTOMER PO:** N/A

**NEA ID:** AK02152 **NEA LRF:** 07030105-01  
**DATE SAMPLED:** 02/11/2007 **TIME:** 12:55  
**PROJECT:** I S 181 PABLO CASALS  
**LOCATION:** BRONX, NY  
**LAB ELAP#:** 11078

<b>PARAMETER PERFORMED</b>	<b>RESULTS</b>	<b>PQL</b>	<b>UNITS</b>	<b>DATE ANALYZED</b>	<b>FLAGS</b>
<b>SW-846 8082 (PCB)</b>					
Aroclor 1016	ND	221	ug/g	04/05/2007	U
Aroclor 1221	ND	221	ug/g	04/05/2007	U
Aroclor 1232	ND	221	ug/g	04/05/2007	U
Aroclor 1242	ND	221	ug/g	04/05/2007	U
Aroclor 1248	ND	221	ug/g	04/05/2007	U
Aroclor 1254	6180	221	ug/g	04/05/2007	
Aroclor 1260	ND	221	ug/g	04/05/2007	U
Total PCB Amount > Reporting Limit	6180				

Notes: ND (Not Detected). Denotes analyte not detected at a concentration greater than the PQL.  
PQL (Practical Quantitation Limit). Denotes lowest analyte concentration reportable for the sample.

**AUTHORIZED SIGNATURE:**

William A. Kotas  
Quality Assurance Officer

Robert E. Wagner  
Laboratory Director