

Sample: 002 CR-001 WINDOW CAULK  
(Continued)

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB-1248	EPA 8082	ND	ug/Kg	91700000	NAC	01/05/2007 / 14:00	
PCB-1254	EPA 8082	ND	ug/Kg	91700000	NAC	01/05/2007 / 14:00	
PCB-1260	EPA 8082	109000000	ug/Kg	91700000	NAC	01/05/2007 / 14:00	
PCB-1262	EPA 8082	ND	ug/Kg	91700000	NAC	01/05/2007 / 14:00	
PCB-1268	EPA 8082	ND	ug/Kg	91700000	NAC	01/05/2007 / 14:00	
TCMX (SURROGATE)			%		NAC	01/05/2007 / 14:00	G
DCB (SURROGATE)			%		NAC	01/05/2007 / 14:00	G
PCB OIL/SOIL EXTRACTIONS		1.09			ADW	12/29/2006 / 18:16	
Percent Solids	SM 2540G	100	%		TLL	12/29/2006 / 7:20	

Sample: 003 CR-002 EXT. JOINT CAULK  
Collection Date: 12/20/2006  
Matrix: CAULK

Received Date: 12/28/2006 Time: 1:00:00AM

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	64500000	NAC	01/05/2007 / 13:58	
PCB-1221	EPA 8082	ND	ug/Kg	64500000	NAC	01/05/2007 / 13:58	
PCB-1232	EPA 8082	ND	ug/Kg	64500000	NAC	01/05/2007 / 13:58	
PCB-1242	EPA 8082	ND	ug/Kg	64500000	NAC	01/05/2007 / 13:58	
PCB-1248	EPA 8082	ND	ug/Kg	64500000	NAC	01/05/2007 / 13:58	
PCB-1254	EPA 8082	81100000	ug/Kg	64500000	NAC	01/05/2007 / 13:58	
PCB-1260	EPA 8082	ND	ug/Kg	64500000	NAC	01/05/2007 / 13:58	
PCB-1262	EPA 8082	ND	ug/Kg	64500000	NAC	01/05/2007 / 13:58	
PCB-1268	EPA 8082	ND	ug/Kg	64500000	NAC	01/05/2007 / 13:58	
TCMX (SURROGATE)			%		NAC	01/05/2007 / 13:58	G
DCB (SURROGATE)			%		NAC	01/05/2007 / 13:58	G
PCB OIL/SOIL EXTRACTIONS		1.55			ADW	12/29/2006 / 18:16	
Percent Solids	SM 2540G	100	%		TLL	12/29/2006 / 7:20	

Sample: 004 MC-001 EXT. JOINT CAULK  
Collection Date: 12/20/2006  
Matrix: CAULK

Received Date: 12/28/2006 Time: 1:00:00AM