



Customer: Eisenbach & Ruhnke Engineering

Workorder No. 0612-00317

Sample: 006 LK-006 LOUVER CAULK

Collection Date: 12/20/2006

Received Date: 12/28/2006 Time: 1:00:00AM

Matrix: CAULK

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	70900	MVP	01/04/2007 / 6:00	
PCB-1221	EPA 8082	ND	ug/Kg	70900	MVP	01/04/2007 / 6:00	
PCB-1232	EPA 8082	ND	ug/Kg	70900	MVP	01/04/2007 / 6:00	
PCB-1242	EPA 8082	ND	ug/Kg	70900	MVP	01/04/2007 / 6:00	
PCB-1248	EPA 8082	ND	ug/Kg	70900	MVP	01/04/2007 / 6:00	
PCB-1254	EPA 8082	96800	ug/Kg	70900	MVP	01/04/2007 / 6:00	
PCB-1260	EPA 8082	ND	ug/Kg	70900	MVP	01/04/2007 / 6:00	
PCB-1262	EPA 8082	ND	ug/Kg	70900	MVP	01/04/2007 / 6:00	
PCB-1268	EPA 8082	ND	ug/Kg	70900	MVP	01/04/2007 / 6:00	
TCMX (SURROGATE)		83.7	%		MVP	01/04/2007 / 6:00	
DCB (SURROGATE)		163.2	%		MVP	01/04/2007 / 6:00	
PCB OIL/SOIL EXTRACTIONS		1.41			ADW	12/29/2006 / 18:11	
Percent Solids	SM 2540G	100	%		TLL	12/29/2006 / 7:20	

G Surrogate recoveries are not reported due to sample dilution.

To the best of my knowledge this report is true and accurate.

Authorized By:

Nicole Cortese, Client Services Manager

Date:

1/8/07

NOTE: All solid results are reported on a dry weight basis unless otherwise noted.