

Sample: 004 MG-001 LOUVER CAULK  
(Continued)

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	6670	NAC	01/05/2007 / 15:00	
PCB-1221	EPA 8082	ND	ug/Kg	6670	NAC	01/05/2007 / 15:00	
PCB-1232	EPA 8082	ND	ug/Kg	6670	NAC	01/05/2007 / 15:00	
PCB-1242	EPA 8082	ND	ug/Kg	6670	NAC	01/05/2007 / 15:00	
PCB-1248	EPA 8082	ND	ug/Kg	6670	NAC	01/05/2007 / 15:00	
PCB-1254	EPA 8082	23700	ug/Kg	6670	NAC	01/05/2007 / 15:00	
PCB-1260	EPA 8082	ND	ug/Kg	6670	NAC	01/05/2007 / 15:00	
PCB-1262	EPA 8082	ND	ug/Kg	6670	NAC	01/05/2007 / 15:00	
PCB-1268	EPA 8082	ND	ug/Kg	6670	NAC	01/05/2007 / 15:00	
TCMX (SURROGATE)		78.4	%		NAC	01/05/2007 / 15:00	
DCB (SURROGATE)		106	%		NAC	01/05/2007 / 15:00	
PCB OIL/SOIL EXTRACTIONS		1.50			ADW	12/29/2006 / 18:11	
Percent Solids	SM 2540G	100	%		TLL	12/29/2006 / 7:20	

Sample: 005 MG-002 KITCHEN DOOR CAULK

Collection Date: 12/20/2006

Received Date: 12/28/2006 Time: 1:00:00AM

Matrix: CAULK

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	6130000	NAC	01/05/2007 / 12:00	
PCB-1221	EPA 8082	ND	ug/Kg	6130000	NAC	01/05/2007 / 12:00	
PCB-1232	EPA 8082	ND	ug/Kg	6130000	NAC	01/05/2007 / 12:00	
PCB-1242	EPA 8082	ND	ug/Kg	6130000	NAC	01/05/2007 / 12:00	
PCB-1248	EPA 8082	ND	ug/Kg	6130000	NAC	01/05/2007 / 12:00	
PCB-1254	EPA 8082	75600000	ug/Kg	6130000	NAC	01/05/2007 / 12:00	
PCB-1260	EPA 8082	ND	ug/Kg	6130000	NAC	01/05/2007 / 12:00	
PCB-1262	EPA 8082	ND	ug/Kg	6130000	NAC	01/05/2007 / 12:00	
PCB-1268	EPA 8082	ND	ug/Kg	6130000	NAC	01/05/2007 / 12:00	
TCMX (SURROGATE)			%		NAC	01/05/2007 / 12:00	G
DCB (SURROGATE)			%		NAC	01/05/2007 / 12:00	G
PCB OIL/SOIL EXTRACTIONS		1.63			ADW	12/29/2006 / 18:11	
Percent Solids	SM 2540G	100	%		TLL	12/29/2006 / 7:20	