



Customer: Eisenbach & Ruhnke Engineering

Workorder No. 0612-00318

Sample: 006 MG-003 DOOR & WINDOW SYSTEM CAULK

Collection Date: 12/20/2006

Received Date: 12/28/2006 Time: 1:00:00AM

Matrix: CAULK

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	83300	MVP	01/04/2007 / 3:00	
PCB-1221	EPA 8082	ND	ug/Kg	83300	MVP	01/04/2007 / 3:00	
PCB-1232	EPA 8082	ND	ug/Kg	83300	MVP	01/04/2007 / 3:00	
PCB-1242	EPA 8082	ND	ug/Kg	83300	MVP	01/04/2007 / 3:00	
PCB-1248	EPA 8082	ND	ug/Kg	83300	MVP	01/04/2007 / 3:00	
PCB-1254	EPA 8082	132000	ug/Kg	83300	MVP	01/04/2007 / 3:00	
PCB-1260	EPA 8082	ND	ug/Kg	83300	MVP	01/04/2007 / 3:00	
PCB-1262	EPA 8082	ND	ug/Kg	83300	MVP	01/04/2007 / 3:00	
PCB-1268	EPA 8082	ND	ug/Kg	83300	MVP	01/04/2007 / 3:00	
TCMX (SURROGATE)		73.9	%		MVP	01/04/2007 / 3:00	
DCB (SURROGATE)		163.5	%		MVP	01/04/2007 / 3:00	
PCB OIL/SOIL EXTRACTIONS		1.20			ADW	12/29/2006 / 18:11	
Percent Solids	SM 2540G	100	%		TLL	12/29/2006 / 7:20	

Sample: 007 MG-004 STUCCO CAULK

Collection Date: 12/20/2006

Received Date: 12/28/2006 Time: 1:00:00AM

Matrix: CAULK

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	7350000	NAC	01/05/2007 / 15:00	
PCB-1221	EPA 8082	ND	ug/Kg	7350000	NAC	01/05/2007 / 15:00	
PCB-1232	EPA 8082	ND	ug/Kg	7350000	NAC	01/05/2007 / 15:00	
PCB-1242	EPA 8082	ND	ug/Kg	7350000	NAC	01/05/2007 / 15:00	
PCB-1248	EPA 8082	ND	ug/Kg	7350000	NAC	01/05/2007 / 15:00	
PCB-1254	EPA 8082	28200000	ug/Kg	7350000	NAC	01/05/2007 / 15:00	
PCB-1260	EPA 8082	ND	ug/Kg	7350000	NAC	01/05/2007 / 15:00	
PCB-1262	EPA 8082	ND	ug/Kg	7350000	NAC	01/05/2007 / 15:00	
PCB-1268	EPA 8082	ND	ug/Kg	7350000	NAC	01/05/2007 / 15:00	
TCMX (SURROGATE)			%		NAC	01/05/2007 / 15:00	G
DCB (SURROGATE)			%		NAC	01/05/2007 / 15:00	G