



Customer: Eisenbach & Ruhnke Engineering

Workorder No. 0612-00320

Sample: 004 MC-001 EXT. JOINT CAULK
(Continued)

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	69400	NAC	01/05/2007 / 13:58	
PCB-1221	EPA 8082	ND	ug/Kg	69400	NAC	01/05/2007 / 13:58	
PCB-1232	EPA 8082	ND	ug/Kg	69400	NAC	01/05/2007 / 13:58	
PCB-1242	EPA 8082	ND	ug/Kg	69400	NAC	01/05/2007 / 13:58	
PCB-1248	EPA 8082	ND	ug/Kg	69400	NAC	01/05/2007 / 13:58	
PCB-1254	EPA 8082	256000	ug/Kg	69400	NAC	01/05/2007 / 13:58	R10
PCB-1260	EPA 8082	ND	ug/Kg	69400	NAC	01/05/2007 / 13:58	
PCB-1262	EPA 8082	ND	ug/Kg	69400	NAC	01/05/2007 / 13:58	
PCB-1268	EPA 8082	ND	ug/Kg	69400	NAC	01/05/2007 / 13:58	
TCMX (SURROGATE)			%		NAC	01/05/2007 / 13:58	G
DCB (SURROGATE)			%		NAC	01/05/2007 / 13:58	G
PCB OIL/SOIL EXTRACTIONS		1.44			ADW	12/29/2006 / 18:16	
Percent Solids	SM 2540G	100	%		TLL	12/29/2006 / 7:20	

Sample: 005 MC-002 DOOR CAULK
Collection Date: 12/20/2006
Matrix: CAULK

Received Date: 12/28/2006 Time: 1:00:00AM

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	80600	MVP	01/04/2007 / 15:32	RL5
PCB-1221	EPA 8082	ND	ug/Kg	80600	MVP	01/04/2007 / 15:32	RL5
PCB-1232	EPA 8082	ND	ug/Kg	80600	MVP	01/04/2007 / 15:32	RL5
PCB-1242	EPA 8082	ND	ug/Kg	80600	MVP	01/04/2007 / 15:32	RL5
PCB-1248	EPA 8082	ND	ug/Kg	80600	MVP	01/04/2007 / 15:32	RL5
PCB-1254	EPA 8082	ND	ug/Kg	80600	MVP	01/04/2007 / 15:32	RL5
PCB-1260	EPA 8082	ND	ug/Kg	80600	MVP	01/04/2007 / 15:32	RL5
PCB-1262	EPA 8082	ND	ug/Kg	80600	MVP	01/04/2007 / 15:32	RL5
PCB-1268	EPA 8082	ND	ug/Kg	80600	MVP	01/04/2007 / 15:32	RL5
TCMX (SURROGATE)			%		MVP	01/04/2007 / 15:32	G
DCB (SURROGATE)			%		MVP	01/04/2007 / 15:32	G
PCB OIL/SOIL EXTRACTIONS		1.24			ADW	12/29/2006 / 18:16	
Percent Solids	SM 2540G	100	%		TLL	12/29/2006 / 7:20	