



## Laboratory Report

Report Date 01/08/2007  
 Workorder No. 0612-00319

Customer: Eisenbach & Ruhnke Engineering  
 291 Genesee Street  
 Utica, NY 13501

Attention: Matt Inman  
 Subject: FLEET WOOD

Sample: 001 FW-001 DOOR CAULK ADDITION  
 Collection Date: 12/20/2006  
 Matrix: CAULK

Received Date: 12/28/2006 Time: 1:00:00AM

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	62900	MVP	01/04/2007 / 19:00	
PCB-1221	EPA 8082	ND	ug/Kg	62900	MVP	01/04/2007 / 19:00	
PCB-1232	EPA 8082	ND	ug/Kg	62900	MVP	01/04/2007 / 19:00	
PCB-1242	EPA 8082	ND	ug/Kg	62900	MVP	01/04/2007 / 19:00	
PCB-1248	EPA 8082	ND	ug/Kg	62900	MVP	01/04/2007 / 19:00	
PCB-1254	EPA 8082	1280000	ug/Kg	62900	MVP	01/04/2007 / 19:00	
PCB-1260	EPA 8082	ND	ug/Kg	62900	MVP	01/04/2007 / 19:00	
PCB-1262	EPA 8082	ND	ug/Kg	62900	MVP	01/04/2007 / 19:00	
PCB-1268	EPA 8082	ND	ug/Kg	62900	MVP	01/04/2007 / 19:00	
TCMX (SURROGATE)			%		MVP	01/04/2007 / 19:00	G
DCB (SURROGATE)			%		MVP	01/04/2007 / 19:00	G
PCB OIL/SOIL EXTRACTIONS		1.59			ADW	12/29/2006 / 18:16	
Percent Solids	SM 2540G	100	%		TLL	12/29/2006 / 7:20	

Sample: 002 FW-002 EXT. JOINT ADDITION  
 Collection Date: 12/20/2006  
 Matrix: CAULK

Received Date: 12/28/2006 Time: 1:00:00AM

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	79400	MVP	01/04/2007 / 16:00	
PCB-1221	EPA 8082	ND	ug/Kg	79400	MVP	01/04/2007 / 16:00	
PCB-1232	EPA 8082	ND	ug/Kg	79400	MVP	01/04/2007 / 16:00	
PCB-1242	EPA 8082	ND	ug/Kg	79400	MVP	01/04/2007 / 16:00	