

## Laboratory Report

Report Date 02/02/2007  
 Workorder No. 0701-00321

Customer: Eisenbach & Ruhnke Engineering  
 291 Genesee Street  
 Utica, NY 13501

Attention: Brian Jones  
 Subject: EXCEL AID 1/29/07

Sample: 001 001 HILLCRES ADDITION CAULK  
 Collection Date: 01/29/2007 Time: 8:00:00AM  
 Matrix: CAULK

Received Date: 01/30/2007 Time: 9:50:00AM

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	1870000	MVP	01/31/2007 / :41	
PCB-1221	EPA 8082	ND	ug/Kg	1870000	MVP	01/31/2007 / :41	
PCB-1232	EPA 8082	ND	ug/Kg	1870000	MVP	01/31/2007 / :41	
PCB-1242	EPA 8082	ND	ug/Kg	1870000	MVP	01/31/2007 / :41	
PCB-1248	EPA 8082	ND	ug/Kg	1870000	MVP	01/31/2007 / :41	
PCB-1254	EPA 8082	44900000	ug/Kg	1870000	MVP	01/31/2007 / :41	
PCB-1260	EPA 8082	ND	ug/Kg	1870000	MVP	01/31/2007 / :41	
PCB-1262	EPA 8082	ND	ug/Kg	1870000	MVP	01/31/2007 / :41	
PCB-1268	EPA 8082	ND	ug/Kg	1870000	MVP	01/31/2007 / :41	
TCMX (SURROGATE)			%		MVP	01/31/2007 / :41	G
DCB (SURROGATE)			%		MVP	01/31/2007 / :41	G
PCB OIL/SOIL EXTRACTIONS		1.07			DLP	01/30/2007 / 16:29	
Percent Solids	SM 2540G	100	%		TLL	01/31/2007 / 6:56	

Sample: 002 002 GYM EXP. JOINT S.P.  
 Collection Date: 01/29/2007 Time: 8:00:00AM  
 Matrix: CAULK

Received Date: 01/30/2007 Time: 9:50:00AM

Parameter	Method	Results	Units	PQL	Tech	Analysis Date/Time	Qual
PCB 8082-SOIL/SOLID							
PCB-1016	EPA 8082	ND	ug/Kg	1630000	MVP	01/31/2007 / :20	
PCB-1221	EPA 8082	ND	ug/Kg	1630000	MVP	01/31/2007 / :20	
PCB-1232	EPA 8082	ND	ug/Kg	1630000	MVP	01/31/2007 / :20	
PCB-1242	EPA 8082	ND	ug/Kg	1630000	MVP	01/31/2007 / :20	