CHAIN OF CUSTODY RECORD

PAGE 1 OF 1

NORTHEAST ANALYTICAL, INC.

2190 Technology Drive, Schenectady, NY 12308
Telephone (518) 346-4592 Fax (518) 381-6055
www.nealab.com information @nealab.com

<09030004P1>

LRF # 090300041

DISPOSAL REQUIREMENTS: (To be filled in by Client)

- ◯ RETURN TO CLIENT
- ◯ DISPOSAL BY NORTHEAST ANALYTICAL
- ◯ ARCHIVAL BY NORTHEAST ANALYTICAL

Additional charges incurred for disposal (if hazardous) or archival. Call for details.

CLIENT (REPORTS TO BE SENT TO):	PROJECT#/PROJECT NAME: A School 3/2/09
PROJECT MANAGER:	PROJECT LOCATION (CITY/STATE) ADDRESS: Burlington, MA 3/2/09
PHONE: 978-663-9234	
SAMPLED BY: (Please Print) George Weymouth	REQUIRED TURN AROUND TIME: STD 3/2/09
SAMPLING FIRM:	NAME OF COURIER (IF USED):
	Data Report: ☐ CLP* ☐ Certificates Only

ELECTRONIC RESULTS FORMAT: PDF ☐ EXCEL (.CSV) ☐ E-MAIL ADDRESS: WEYCOR@MSN.COM

FAXED RESULTS ☐ FAX #:

ENTER ANALYSIS AND METHOD NUMBER REQUESTED

PRESERVATIVE KEY: 0 - NONE; 1 - HCL; 2 - HNO3; 3 - H2SO4; 4 - NaOH; 5 - Zn. Acetate; 6 - MeOH; 7 - NaHSO4; 8 - Other _____

SAMPLE ID	DATE	TIME	MATRIX	GRAB/ COMP	LAB SAMPLE ID (NEA USE ONLY)	NUMBER OF CONTAINERS	PCB	PCB	REMARKS:
BR-C-1	2/25/09	10:Am	Soil		AM01909	1	1		
BR-C-2	2/25/09	10:30AM	Solid		AM01910	1	1		

PRESERVATIVE CODE:
BOTTLE TYPE:
BOTTLE SIZE:

AMBIENT OR CHILLED TEMP: 18.6 COC TAPE: Y (N)
RECEIVED BROKEN OR LEAKING: Y (N) COC DISCREPANCIES: Y (N)
PROPERLY PRESERVED: (Y) N OTHER NOTES:
RECVD W/I HOLDING TIMES: (Y) N

RELINQUISHED BY	RECEIVED BY	RELINQUISHED BY	RECEIVED BY	RELINQUISHED BY	RECEIVED BY
SIGNATURE: George Weymouth	SIGNATURE: A. Moore	SIGNATURE	SIGNATURE	SIGNATURE	SIGNATURE
PRINTED NAME: George Weymouth	PRINTED NAME: A. MOORE	PRINTED NAME	PRINTED NAME	PRINTED NAME	PRINTED NAME
COMPANY	COMPANY: NEA	COMPANY	COMPANY	COMPANY	COMPANY
DATE/TIME: 2-26-09 9AM	DATE/TIME: 3/2/09 900	DATE/TIME	DATE/TIME	DATE/TIME	DATE/TIME

* CLP LIKE DATA PACKAGE ADDITIONAL COST

CERTIFICATE OF ANALYSIS
03/05/2009
GEORGE WEYMOUTH
6 AGAWAM CIR
BILLERICA, MA 01821
CONTACT: GEORGE WEYMOUTH

CUSTOMER ID: BR-C-1 **NEA ID:** AM01909 **NEA LRF:** 09030004-01
MATRIX: CAULK **DATE SAMPLED:** 02/25/2009 **TIME:** 10:00
DATE RECEIVED: 03/02/2009 **TIME:** 09:00 **PROJECT:** A SCHOOL
SAMPLED BY: G. WEYMOUTH **LOCATION:** BURLINGTON, MA
CUSTOMER PO: N/A **LAB ELAP#:** 11078

PARAMETER PERFORMED	RESULTS	PQL	UNITS	DATE ANALYZED	FLAGS
SW-846 8082 (PCB)					
Aroclor 1016	ND	1640	ug/g	03/05/2009	U
Aroclor 1221	ND	1640	ug/g	03/05/2009	U
Aroclor 1232	ND	1640	ug/g	03/05/2009	U
Aroclor 1242	ND	1640	ug/g	03/05/2009	U
Aroclor 1248	ND	1640	ug/g	03/05/2009	U
Aroclor 1254	ND	1640	ug/g	03/05/2009	U
Aroclor 1260	73500	1640	ug/g	03/05/2009	
Total PCB Amount > Reporting Limit	73500				

Notes: ND (Not Detected). Denotes analyte not detected at a concentration greater than the PQL.
PQL (Practical Quantitation Limit). Denotes lowest analyte concentration reportable for the sample.

AUTHORIZED SIGNATURE:

William A. Kotas
Sr. Laboratory Representative

Robert E. Wagner
Laboratory Director

This report may not be reproduced except in full, without the written approval of Northeast Analytical, Inc.

2190 Technology Drive Schenectady, NY 12308 Phone 518.346.4592 Fax 518.381.6055 Email : information@nealab.com

CERTIFICATE OF ANALYSIS
03/05/2009
GEORGE WEYMOUTH
6 AGAWAM CIR
BILLERICA, MA 01821
CONTACT: GEORGE WEYMOUTH

CUSTOMER ID: BR-C-2 **NEA ID:** AM01910 **NEA LRF:** 09030004-02
MATRIX: CAULK **DATE SAMPLED:** 02/25/2009 **TIME:** 10:30
DATE RECEIVED: 03/02/2009 **TIME:** 09:00 **PROJECT:** A SCHOOL
SAMPLED BY: G. WEYMOUTH **LOCATION:** BURLINGTON, MA
CUSTOMER PO: N/A **LAB ELAP#:** 11078

PARAMETER PERFORMED	RESULTS	PQL	UNITS	DATE ANALYZED	FLAGS
SW-846 8082 (PCB)					
Aroclor 1016	ND	1650	ug/g	03/05/2009	U
Aroclor 1221	ND	1650	ug/g	03/05/2009	U
Aroclor 1232	ND	1650	ug/g	03/05/2009	U
Aroclor 1242	ND	1650	ug/g	03/05/2009	U
Aroclor 1248	ND	1650	ug/g	03/05/2009	U
Aroclor 1254	ND	1650	ug/g	03/05/2009	U
Aroclor 1260	75100	1650	ug/g	03/05/2009	
Total PCB Amount > Reporting Limit	75100				

Notes: ND (Not Detected). Denotes analyte not detected at a concentration greater than the PQL.
PQL (Practical Quantitation Limit). Denotes lowest analyte concentration reportable for the sample.

AUTHORIZED SIGNATURE:

William A. Kotas
Sr. Laboratory Representative

Robert E. Wagner
Laboratory Director

This report may not be reproduced except in full, without the written approval of Northeast Analytical, Inc.

2190 Technology Drive Schenectady, NY 12308 Phone 518.346.4592 Fax 518.381.6055 Email : information@nealab.com