



**Experience is the solution**

314 North Pearl Street ♦ Albany, New York 12207  
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

April 27, 2008

Aleksandr Knobel  
ALAC  
522 East 20th Street, Suite 6E  
New York, NY 10009

Work Order No: 080427001

TEL: (212) 290-6323  
FAX: (212) 290-6325

RE: SCA PCB Sampling  
330 Durant Ave. Staten Island, NY

Dear Aleksandr Knobel:

Adirondack Environmental Services, Inc received 21 samples on 4/27/2008 for the analyses presented in the following report.

There were no problems with the analyses and all associated QC met EPA or laboratory specifications, except if noted.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709  
AIHA#: 100307

Tara Daniels  
Laboratory Manager

Aleksandr Knobel - FAX

**Analytical Results  
for  
ALAC**

**WorkOrder: 080427001**

**Client Reference: SCA PCB Sampling / 330 Durant Ave. Staten Island, NY**

**PO#:**

Analyte	Concentration			LOQ (ug)	Qual	Test Method	Date Analyzed /Analyst
	(ug)	(mg/m <sup>3</sup> )	(ppm)				

Client ID: 2nd Fl. Cafeteria	Lab ID: 001A	Date Sampled: 4/26/2008	Air Vol.(L): 90				
Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

Client ID: 2nd Fl. Gymnasium	Lab ID: 002A	Date Sampled: 4/26/2008	Air Vol.(L): 90				
Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

Client ID: 2nd Fl. Auditorium	Lab ID: 003A	Date Sampled: 4/26/2008	Air Vol.(L): 90				
Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

Client ID: 2nd Fl. Room 233	Lab ID: 004A	Date Sampled: 4/26/2008	Air Vol.(L): 90				
Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

Client ID: 2nd Fl. Room 214	Lab ID: 005A	Date Sampled: 4/26/2008	Air Vol.(L): 90				
Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Analytical Results  
for  
ALAC**

**WorkOrder: 080427001**

**Client Reference: SCA PCB Sampling / 330 Durant Ave. Staten Island, NY**

**PO#:**

Analyte	Concentration			LOQ (ug)	Qual	Test Method	Date Analyzed /Analyst
	(ug)	(mg/m <sup>3</sup> )	(ppm)				

**Client ID: 2nd Fl. Room 205      Lab ID: 006A      Date Sampled: 4/26/2008      Air Vol.(L): 90**

Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Client ID: 2nd Fl. Room 202      Lab ID: 007A      Date Sampled: 4/26/2008      Air Vol.(L): 90**

Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Client ID: 1st. Fl. Room 134      Lab ID: 008A      Date Sampled: 4/26/2008      Air Vol.(L): 90**

Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Client ID: 1st. Fl. Room 114      Lab ID: 009A      Date Sampled: 4/26/2008      Air Vol.(L): 90**

Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Client ID: 1st. Fl. Room 102      Lab ID: 010A      Date Sampled: 4/26/2008      Air Vol.(L): 90**

Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Analytical Results  
for  
ALAC**

**WorkOrder: 080427001**

**Client Reference: SCA PCB Sampling / 330 Durant Ave. Staten Island, NY**

**PO#:**

Analyte	Concentration			LOQ (ug)	Qual	Test Method	Date Analyzed /Analyst
	(ug)	(mg/m <sup>3</sup> )	(ppm)				

Client ID: 1st. Fl. Room 101	Lab ID: 011A	Date Sampled: 4/26/2008	Air Vol.(L): 90				
Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

Client ID: 3rd Fl. Room 337	Lab ID: 012A	Date Sampled: 4/26/2008	Air Vol.(L): 90				
Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

Client ID: 3rd Fl. Room 324	Lab ID: 013A	Date Sampled: 4/26/2008	Air Vol.(L): 90				
Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

Client ID: 3rd Fl. Room 306	Lab ID: 014A	Date Sampled: 4/26/2008	Air Vol.(L): 90				
Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

Client ID: 3rd Fl. Room 305	Lab ID: 015A	Date Sampled: 4/26/2008	Air Vol.(L): 90				
Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Analytical Results  
for  
ALAC**

**WorkOrder: 080427001**

**Client Reference: SCA PCB Sampling / 330 Durant Ave. Staten Island, NY**

**PO#:**

Analyte	Concentration			LOQ (ug)	Qual	Test Method	Date Analyzed /Analyst
	(ug)	(mg/m <sup>3</sup> )	(ppm)				

**Client ID: Exterior by Room 233      Lab ID: 016A      Date Sampled: 4/26/2008      Air Vol.(L): 90**

Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Client ID: Exterior by Kitchen      Lab ID: 017A      Date Sampled: 4/26/2008      Air Vol.(L): 90**

Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Client ID: Exterior by Room 106      Lab ID: 018A      Date Sampled: 4/26/2008      Air Vol.(L): 90**

Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Client ID: Exterior by Room 120      Lab ID: 019A      Date Sampled: 4/26/2008      Air Vol.(L): 90**

Aroclor 1016	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	<0.000333	--	0.03	Niosh 5503	04/27/2008	KF

**Client ID: Blank      Lab ID: 020A      Date Sampled: 4/26/2008      Air Vol.(L): NA**

Aroclor 1016	<0.0300	--	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1221	<0.0300	--	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1232	<0.0300	--	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1242	<0.0300	--	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1248	<0.0300	--	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1254	<0.0300	--	--	0.03	Niosh 5503	04/27/2008	KF
Aroclor 1260	<0.0300	--	--	0.03	Niosh 5503	04/27/2008	KF

Analytical Results  
for  
ALAC

WorkOrder: **080427001**

Client Reference: SCA PCB Sampling / 330 Durant Ave. Staten Island, NY

PO#:

Analyte	Concentration			LOQ (ug)	Qual	Test Method	Date Analyzed /Analyst
	(ug)	(mg/m <sup>3</sup> )	(ppm)				
Client ID: Blank	Lab ID: 021A    Date Sampled: 4/26/2008			Air Vol.(L): NA			
Aroclor 1016	<0.0300	--	--	0.03		Niosh 5503	04/27/2008 KF
Aroclor 1221	<0.0300	--	--	0.03		Niosh 5503	04/27/2008 KF
Aroclor 1232	<0.0300	--	--	0.03		Niosh 5503	04/27/2008 KF
Aroclor 1242	<0.0300	--	--	0.03		Niosh 5503	04/27/2008 KF
Aroclor 1248	<0.0300	--	--	0.03		Niosh 5503	04/27/2008 KF
Aroclor 1254	<0.0300	--	--	0.03		Niosh 5503	04/27/2008 KF
Aroclor 1260	<0.0300	--	--	0.03		Niosh 5503	04/27/2008 KF

General Notes:

<: Less than the indicated Limit of Quantitation (LOQ).

--: Information not available or not applicable.

Results have not been Blank Corrected



WBE Certified  
www.CEScenter.com

**Creative Environment Solutions Corporation**  
One Penn Plaza • 7<sup>th</sup> Floor • New York • NY 10119  
(212) 290 - 6323 • FAX (212) 290 - 6325

**SAMPLING CHAIN-OF-CUSTODY FORM**

PAGE ( 1 OF 2 )

Date Collected: <u>04/26/08</u>	Project Name: SCA PCB Sampling @ PS53R	Client: NYC SCA
Collected by: <u>T. Lintsko</u>	Location: 330 Durant Avenue, Staten Island, NY 10301	LLW#:
		SCA Job#:
		CES Project/Task:

Task / Activity:  Background,  Pre-Abatement/Clean-Up,  During Abatement/Clean-Up,  
 Post Abatement/Clean-Up, Inspection,  Repair/ Interim Control,  
 Construction/Alteration/Demolition,  Other:  Ambient

Matrix: S = SOIL; L = LIQUID; A = AIR; SL = SLUDGE; W = WIPE; P = PAINT CHIPS; B = BULK MATERIAL

Laboratory:  ALAC ; ELAP No 11506  
 Adirondack Env. ; ELAP No 10709  
 JMS ; ELAP No 11715  
 York Labs ; ELAP No. 10854

Analysis Requested:  NIOSH 7400A,  
 TEM (AHERA)  
 Other:  
 As Indicated

080427  
02

Sample ID	Matrix	Flow Rate		Average Flow Rate	Time		Total Minutes	Total Volume	Sample Location / Description	Analysis Requested/Results:				
		Start	Finish		Start	Finish				Asbestos	PCB EPA 8062	Mercury	Pb,Cr,Cd,As	SVOC - 4 Phthalates
01	A	1	1	1	18:10	19:40	90	90	2 <sup>nd</sup> FL. Cafeteria		X			
02	A	1	1	1	18:13	19:43	90	90	2 <sup>nd</sup> FL. Gymnasium		X			
03	A	1	1	1	18:17	19:47	90	90	2 <sup>nd</sup> FL. Auditorium		X			
04	A	1	1	1	18:20	19:50	90	90	2 <sup>nd</sup> FL. Room 233		X			
05	A	1	1	1	18:23	19:53	90	90	2 <sup>nd</sup> FL. Room 214		X			
06	A	1	1	1	18:26	19:56	90	90	2 <sup>nd</sup> FL. Room 205		X			
07	A	1	1	1	18:29	19:59	90	90	2 <sup>nd</sup> FL. Room 202		X			
08	A	1	1	1	18:35	20:05	90	90	1 <sup>st</sup> FL. Room 134		X			
09	A	1	1	1	18:38	20:08	90	90	1 <sup>st</sup> FL. Room 114		X			
10	A	1	1	1	18:41	20:11	90	90	1 <sup>st</sup> FL. Room 102		X			
11	A	1	1	1	18:44	20:14	90	90	1 <sup>st</sup> FL. Room 101		X			
12	A	1	1	1	19:00	20:30	90	90	3 <sup>rd</sup> FL. Room 337		X			
13	A	1	1	1	19:05	20:35	90	90	3 <sup>rd</sup> FL. Room 324		X			
14	A	1	1	1	19:08	20:38	90	90	3 <sup>rd</sup> FL. Room 306		X			
15	A	1	1	1	19:12	20:42	90	90	3 <sup>rd</sup> FL. Room 305		X			
16	A	1	1	1	19:20	20:50	90	90	Exterior by Room 233		X			

Turn-Around-Time:  Immediate,  12 Hr,  24 Hr,  48 Hr,  72 Hr Results to: X Fax: 212-290-6325

3-5 Days,  5-10 Days, Other \_\_\_\_\_

X E-mail: CESLabResults@aol.com

Special Instructions: \_\_\_\_\_

Other: \_\_\_\_\_

Site		Laboratory	
Relinquished By	Delivery Method	Received By	Date
G. Dumitrescu	by hand	JL Zuller	4/27/08 7:00 AM



# Creative Environment Solutions Corporation

One Penn Plaza • 7<sup>th</sup> Floor • New York • NY 10119

(212) 290 - 6323 • FAX (212) 290 - 6325

## SAMPLING CHAIN-OF-CUSTODY FORM

PAGE (2 OF 2)

Date Collected: <i>04/26/08</i>	Project Name: SCA PCB Sampling @ PS53R	Client: NYC SCA
Collected by: <i>T. Linters</i>	Location: 330 Durant Avenue, Staten Island, NY 10301	LLW#:
		SCA Job#:
		CES Project/Task:

Task / Activity:  Background,  Pre-Abatement/Clean-Up,  During Abatement/Clean-Up,  
 Post Abatement/Clean-Up, Inspection,  Repair/ Interim Control,  
 Construction/Alteration/Demolition,  Other:  Ambient

Matrix: S = SOIL; L = LIQUID; A = AIR; SL = SLUDGE; W = WIPE; P = PAINT CHIPS; B = BULK MATERIAL

Laboratory:  ALAC ; ELAP No 11506      Analysis Requested:  NIOSH 7400A,  
 Adirondack Env. ELAP No. 10709       TEM (AHERA)  
 JMS ; ELAP No 11715       Other:  
 York Labs ; ELAP No. 10854       As Indicated

427  
001

Sample ID	Matrix	Flow Rate		Average Flow Rate	Time		Total Minutes	Total Volume	Sample Location / Description	Analysis Requested/Results:				
		Start	Finish		Start	Finish				Asbestos	PCB EPA 8092	Mercury	Pb, Cr, Cd, As	SVOC - 4 Phthalates
17	A	1	1	1	19:23	20:53	90	90	Exterior by kitchen		X			
18	A	1	1	1	19:27	20:57	90	90	Exterior by Room 106		X			
19	A	1	1	1	19:30	21:00	90	90	Exterior by Room 120		X			
20	A								Blank		X			
21	A								Blank		X			

Turn-Around-Time:  Immediate,  12 Hr,  24 Hr,  48 Hr,  72 Hr      Results to: X Fax: 212-290-6325  
 3-5 Days,  5-10 Days, Other \_\_\_\_\_      X E-mail: CESLabResults@aol.com  
Special Instructions: \_\_\_\_\_       Other: \_\_\_\_\_

Site		Laboratory	
Relinquished By	Delivery Method	Received By	Date
G. Down's etc	by hand	MS Fuller	4/27/08 7:00 AM